



**GENERAL NOTES:**

1. THIS PLAN DOES NOT REPRESENT A PROPERTY BOUNDARY SURVEY.
2. AT THE TIME OF THE AS-BUILT INSPECTION NO GARBAGE GRINDERS WERE INSTALLED ON THIS SYSTEM. SYSTEM IS NOT DESIGN FOR GARBAGE GRINDER USE.
3. ADVISE PUMPING THE SEPTIC TANK EVERY 1 TO 3 YEARS DEPENDING ON USAGE.
4. ADVISE CLEANING OF EFFLUENT FILTER EVERY 6 MONTHS.
5. FOR FUTURE INSPECTIONS, THE DISTRIBUTION BOX COVER IS APPROXIMATELY 12" BELOW FINISH GRADE. FIELD IS MARKED WITH MAGNETIC DETECTION TAPE.
6. VEHICULAR TRAFFIC IS PROHIBITED OVER SYSTEM COMPONENTS.
7. ALL PIPING INSTALLED ON THIS PROJECT WAS SCHEDULE 40 PVC PIPING, INSTALLED WITH APPROPRIATE GLUE.
8. DO NOT PUMP SEPTIC TANK IN HIGH GROUND WATER SEASONS (SPRING AND FALL). IF SO LEAVE APPROXIMATELY 8"-12" OF WATER IN THE BOTTOM OF TANK AFTER PUMPING FOR BUOYANCY.

LOCATION	SWING TIE DISTANCES	
	LINE SEGMENT	DISTANCE
INVERT COVER (SEPTIC TANK)	A - C	13'-10"
	B - C	79'-10"
OUTLET COVER (SEPTIC TANK)	A - D	20'-10"
	B - D	82'-0"
D-BOX (INSPECTION PORT)	A - E	22'-2"
	B - E	73'-6"
INSPECTION PORT	A - F	40'-3"
	B - F	46'-10"
CLEANOUT	A - G	46'-9"
	B - G	43'-6"
CLEANOUT	A - H	42'-7"
	B - H	38'-0"
CLEANOUT	A - I	22'-0"
	J - I	15'-3"

**AS BUILT ELEVATIONS**

	AS-BUILT	DESIGN
NEW INVERT AT FOUNDATION:	61.69'	61.70'
EXIST INVERT TO SEPTIC TANK:	61.02'	61.00'
EXIST EFFLUENT FROM SEPTIC TANK:	60.76'	60.75'
INVERT TO D-BOX:	60.43'	60.42'
EFFLUENT LEAVING D-BOX:	60.26'	60.25'
INVERT TO GEOMATT:	60.03'	60.08'

THE BUILDING SEWER OUTLET(S) SHOWN ON THIS PLAN (ARE) BASED ON BEST AVAILABLE INFORMATION AT THE TIME OF THE AS-BUILT INSPECTION. ANY DESIGN OR CONSTRUCTION COSTS ASSOCIATED WITH ADDITIONAL OUTLETS LATER REVEALED LATER BECOME THE RESPONSIBILITY OF THE OWNER(S). THE INSTALLER BY VIRTUE OF INSTALLING THIS SEPTIC SYSTEM CERTIFIES THAT ALL WASTEWATER FLOW IS PLUMBED TO THE NEW SEPTIC TANK TO BE DISTRIBUTED TO THE SOIL ABSORPTION SYSTEM.

THIS SYSTEM HAS BEEN DESIGNED FOR A THREE BEDROOM DWELLING. SYSTEM HAS BEEN DESIGNED FOR 330 GPD CAPACITY.

I CERTIFY TO THE BEST OF MY KNOWLEDGE THIS SYSTEM HAS BEEN CONSTRUCTED IN COMPLIANCE WITH 310 CMR 15.00 (TITLE - 5), THE APPROVED DESIGN PLAN, ALL REQUIREMENTS, AND ANY CHANGES OR ALTERATIONS HAVE BEEN REFLECTED IN THIS AS BUILT.

AS-BUILT SUB-SURFACE DOMESTIC WASTEWATER DISPOSAL AND TREATMENT SYSTEM - RESIDENTIAL HOME  
115 TALBOT WAY, SEEKONK, MA 02771

SCALE: AS SHOWN ON DRAWINGS

**PREPARED FOR:**  
WESTBRIAR PROPERTIES  
134 EBONY STREET  
FAIRHAVEN, MA 02719

**PROJECT LOCATION:**  
115 TALBOT WAY  
SEEKONK, MA 02771

OAKHILL ENGINEERING  
75 OAKHILL AVE, 2ND FL  
SEEKONK, MA 02771  
401-574-0871  
MARK4026@GMAIL.COM

DRAWN BY: MPM  
REVIEWED BY: MPM

DATE: 12/30/22

